



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 3

**Violations Comments**

<p>Violation #5. Maintenance &amp; Repair Water stained ceiling tiles in media center (room7-113). Replace ceiling tiles.</p> <p>Broken floor tiles in media center (room7-113). Replace broken floor tiles.</p> <p>Broken dry wall in classroom 9-1 and 8-208. Plaster wall and retouch paint.</p> <p>Chipped wall paint in classroom 8-209. Scrape wall and retouch paint.</p> <p>Rust in sink of classroom 8-120. Repair sink.</p> <p>Dust buildup on HVAC vents in classroom 9-1. Clean and disinfect.</p> <p>CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components &amp; finishes shall be kept clean &amp; in good repair.</p>
<p>Violation #9. Mechanical Ventilation HVAC Ventilation in bathroom 9-1B not operable. Repair HVAC.</p> <p>CODE REFERENCE: 9. Mechanical Ventilation. 5(16)(a)2 SREF. Mechanical ventilation systems shall be maintained in an operable condition at all times. 5(16)(a)4 SREF. Exhaust systems from toilet rooms, custodial closets, shower and locker rooms, athletic equipment rooms, etc., shall be maintained in an operable condition at all times. 5(13)(g)1.d SREF. Toilet rooms shall have exhaust fans vented to the exterior. 5(16)(a)10 SREF. Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be irritating or injurious to human health shall have an exhaust system to collect and remove the contaminants. Such exhaust shall discharge directly to the exterior of the building. 468.3.6.2 FBC and 468.3.6.3 FBC. Kiln rooms and areas shall be provided with adequate exhaust to dispel emitted heat to the exterior, and they shall not be connected to any other exhaust system. 5(16)(a)5 SREF. Science laboratory fume hoods and laboratory emergency fans shall be maintained in an operable condition. 468.3.6.4 FBC. HVAC systems in chemistry labs and science classrooms shall be designed and installed to ensure that chemicals originating from the space are not recirculated. 468.3.6.5 SREF. Rooms used for the storage, handling, and disposal of chemicals used in school, college, and university laboratories shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.</p>
<p>Violation #12. Toilet Facilities No paper towel in bathroom 9-1B. Replace with paper towel.</p> <p>Scum buildup around sink faucet handle in bathroom 9-1B. Clean and disinfect.</p> <p>Urine odor in bathroom 9-1B. Clean and disinfect.</p> <p>CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean &amp; sanitary condition at all times.</p>

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



3 of 3

Violation #18. Drinking Fountains  
Water fountain with scum buildup in classroom 8-208. Clean and disinfect.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Kimberly Henry (913288)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name: Dunbar, Paul Laurence K-8  
Date: 11/1/2019

Inspector Signature:

A handwritten signature in black ink, appearing to be "K. Henry".

Client Signature:

A handwritten signature in black ink, appearing to be "Paul Laurence Dunbar".